

FIBERTITE AT EXTENDED RADIUS FASCIA

FULLY ADHERED OR MECHANICALLY ATTACHED SINGLE-PLY VERSION

IMPORTANT!!!

**MUST INDICATE PROPER RADIUS CONDITION BY
CIRCLING APPROPRIATE OUTSIDE FACE**

PROVIDING A RADIUS
THE RADIUS MAY BE PROVIDED
IN ONE OF TWO METHODS:


1.) THE ACTUAL KNOWN RADIUS IS

_____ ' FEET _____ " INCHES

OR

2.) FIELD CONDITION MEASUREMENTS

NOTE: REFER TO ATTACHED WORKSHEET
FOR FURTHER INFORMATION




LENGTH OF
STRAIGHT EDGE

NOTE: CHECK MEASUREMENTS ALONG ENTIRE RADIUS.

DETAIL A

MINIMUM OF 4'-6"
(CALL IF LESS)

* RADIUS PRODUCT NOT
REQUIRED IF OVER 150'-0"



* RADIUS EXTRUDED BAR PROVIDED
IN 4'-0" LENGTHS IF RADIUS
IS LESS THAN 48'-0".

* RADIUS EXTRUDED BAR PROVIDED
IN 12'-0" LENGTHS IF RADIUS
IS 48'-0" OR GREATER.

OUTSIDE
FACE

OUTSIDE
FACE

RADIUS
(PROVIDED BY APPROVER
PER DETAIL A)

TOP
VIEW

----- INDICATES AREAS THAT WILL BE SLIT AS
NEEDED TO ACCOMODATE RADIUS

* RADIUS FASCIA
PROVIDED IN 4'-0"
LENGTHS IF RADIUS IS
LESS THAN 48'-0".

* RADIUS FASCIA
PROVIDED IN 12'-0"
LENGTHS IF RADIUS IS
48'-0" OR GREATER.

* RADIUS CLEAT
PROVIDED IN 4'-0"
LENGTHS IF RADIUS IS
LESS THAN 48'-0".

* RADIUS CLEAT
PROVIDED IN 12'-0"
LENGTHS IF RADIUS IS
48'-0" OR GREATER.

FIBERTITE AT EXTENDED RADIUS FASCIA DIMENSIONS

PRODUCT ID. NO.	H DIM	X DIM
<input type="checkbox"/> AEF-85	8 1/2"	7 1/4"
<input type="checkbox"/> AEF-100	10"	8 3/4"
<input type="checkbox"/> AEF-115	11 1/2"	10 1/4"
<input type="checkbox"/> AEF-130	13"	11 3/4"

Fabrication will proceed only after receipt of
signed print approval.

Print Approval:

Architect and/or contractor shall verify all
dimensions, sizes and quantities. All
products to be installed in strict accordance
with FiberTite's printed instructions.

Approved by: _____

Date: _____

MATERIAL:

___ 22 GA. GALV. STEEL ___ .063" ALUMINUM

___ .050" ALUMINUM ___ OTHER _____

COLOR: _____ FINISH: _____

QUANTITIES:

_____ LINEAL FEET 12'-0" LENGTHS

PROJECT:

ARCHITECT:

ROOFING CONTRACTOR:

REPRESENTATIVE/DISTRIBUTOR:

Customer Service

1-800-355-6416



DATE: 11/21/19

DRN BY: JJC

CKD BY: JAI

SHT.# _____ OF _____

DWG# 23010-2428

D